

## Sizing Bus Duct

**Bill's Question:**

“What is the proper way to size Bus Duct?”

**Working Electrician:**

There is not enough information supplied to completely answer your question, but in general assuming this is an industrial building for the busway, 220.3 A of the code requires a computation of 2 volt-amps per square foot of the building just for General Lighting Loads. The rest of the existing loads would have to be added to that computation. We hope this answers your question.